

2/7/11
PM

Delano Municipal Utilities
12470 Volt
Feeder Current Data Report

Device	Hour 13	Hour 14	Hour 15	Hour 16	Hour 17	Hour 18	Hour 19	Hour 20	Hour 21	Hour 22	Hour 23	Hour 24	Minimum Current	Maximum Current
East Loop	1:00 PM	2:00 PM	3:00 PM	4:00 PM	5:00 PM	6:00 PM	7:00 PM	8:00 PM	9:00 PM	10:00 PM	11:00 PM	12:00 AM		
Phase A	155.12	141.87	130.89	99.22	88.90	90.98	77.14	73.81	74.73	71.17	71.49	69.35		
Phase B	151.60	141.14	127.79	100.49	91.22	95.27	84.57	79.40	78.69	76.50	75.44	76.32		
Phase C	155.60	145.51	132.11	100.43	92.02	97.80	87.64	82.07	80.79	76.59	75.45	75.47		
Max	155.60	145.51	132.11	100.49	92.02	97.80	87.64	82.07	80.79	76.59	75.45	76.32		155.60
Min	151.60	141.14	127.79	99.22	88.90	90.98	77.14	73.81	74.73	71.17	71.49	69.35	69.35	
Difference	4.0	4.4	4.3	1.3	3.1	6.8	10.5	8.3	6.1	5.4	4.0	7.0		
West Loop														
Phase A	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00		
Phase B	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00		
Phase C	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00		
Max	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00		0.00
Min	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
Difference	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00	
Delano Crossing														
Phase A	45.25	48.43	45.86	49.92	54.78	66.09	60.24	56.08	53.58	50.59	42.91	40.39		
Phase B	48.64	44.22	47.64	55.88	56.40	65.53	63.80	66.35	57.81	53.52	43.78	43.36		
Phase C	48.74	49.83	46.23	57.60	58.26	67.67	65.99	64.00	57.94	51.78	47.19	41.87		
Max	48.74	49.83	47.64	57.60	58.26	67.67	65.99	66.35	57.94	53.52	47.19	43.36		67.67
Min	45.25	44.22	45.86	49.92	54.78	65.53	60.24	56.08	53.58	50.59	42.91	40.39	40.39	
Difference	3.5	5.6	1.8	7.7	3.5	2.1	5.7	10.3	4.4	2.9	4.3	3.0		
Franklin Ave														
Phase A	2.99	2.64	2.60	3.19	3.57	3.24	3.04	2.34	2.47	1.41	1.87	1.15		
Phase B	8.54	8.59	8.07	7.06	7.11	9.07	8.16	6.27	5.80	5.04	5.29	4.84		
Phase C	29.47	29.51	27.86	29.24	38.92	44.65	47.90	39.59	42.65	39.13	33.81	28.98		
Max	29.47	29.51	27.86	29.24	38.92	44.65	47.90	39.59	42.65	39.13	33.81	28.98		47.90
Min	2.99	2.64	2.60	3.19	3.57	3.24	3.04	2.34	2.47	1.41	1.87	1.15	1.15	
Difference	26.5	26.9	25.3	26.0	35.3	41.4	44.9	37.3	40.2	37.7	31.9	27.8		
South West														
Phase A	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00		
Phase B	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00		
Phase C	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00		
Max	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00		0.00
Min	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
Difference	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00	