

<b>Delano Municipal Utilities</b>															<b>3/11/11</b>	
<b>4160 Volt</b>															<b>AM</b>	
<b>Feeder Current Data Report</b>																
<i>Device</i>	<i>Hour 1</i>	<i>Hour 2</i>	<i>Hour 3</i>	<i>Hour 4</i>	<i>Hour 5</i>	<i>Hour 6</i>	<i>Hour 7</i>	<i>Hour 8</i>	<i>Hour 9</i>	<i>Hour 10</i>	<i>Hour 11</i>	<i>Hour 12</i>	<i>Minimum Current</i>	<i>Maximum Current</i>		
<b>Feeder 1</b>	<b>1:00 AM</b>	<b>2:00 AM</b>	<b>3:00 AM</b>	<b>4:00 AM</b>	<b>5:00 AM</b>	<b>6:00 AM</b>	<b>7:00 AM</b>	<b>8:00 AM</b>	<b>9:00 AM</b>	<b>10:00 AM</b>	<b>11:00 AM</b>	<b>12:00 PM</b>				
<i>Phase A</i>	115.18	105.68	103.66	105.89	102.97	125.68	139.96	166.21	177.97	200.34	177.02	171.78				
<i>Phase B</i>	102.83	94.96	99.98	95.18	85.03	115.29	134.69	158.03	169.20	192.38	164.29	157.29				
<i>Phase C</i>	108.96	99.23	92.16	95.40	97.71	119.52	138.36	160.11	165.65	186.34	167.45	166.55				
<i>Max</i>	115.18	105.68	103.66	105.89	102.97	125.68	139.96	166.21	177.97	200.34	177.02	171.78				
<i>Min</i>	102.83	94.96	92.16	95.18	85.03	115.29	134.69	158.03	165.65	186.34	164.29	157.29	85.03		200.34	
<i>Difference</i>	12.3	10.7	11.5	10.7	17.9	10.4	5.3	8.2	12.3	14.0	12.7	14.5				
<b>Feeder 2</b>																
<i>Phase A</i>	93.88	104.70	97.48	102.80	103.42	111.66	135.97	127.97	114.06	133.65	119.35	121.84				
<i>Phase B</i>	85.80	85.58	75.56	91.47	81.40	88.93	111.45	120.08	104.42	114.58	105.57	92.06				
<i>Phase C</i>	52.03	50.76	43.89	51.59	46.81	46.31	65.23	66.76	62.19	79.39	66.01	64.45				
<i>Max</i>	93.88	104.70	97.48	102.80	103.42	111.66	135.97	127.97	114.06	133.65	119.35	121.84				
<i>Min</i>	52.03	50.76	43.89	51.59	46.81	46.31	65.23	66.76	62.19	79.39	66.01	64.45	43.89		135.97	
<i>Difference</i>	41.9	53.9	53.6	51.2	56.6	65.4	70.7	61.2	51.9	54.3	53.3	57.4				
<b>Feeder 3</b>																
<i>Phase A</i>	20.13	20.46	20.68	20.53	19.31	20.27	22.00	22.54	20.19	23.03	19.59	22.07				
<i>Phase B</i>	20.42	21.53	20.27	20.24	22.59	19.00	20.79	22.10	21.92	20.21	23.82	18.70				
<i>Phase C</i>	22.72	24.54	21.98	26.97	27.55	27.11	33.37	25.85	32.71	29.13	27.26	27.09				
<i>Max</i>	22.72	24.54	21.98	26.97	27.55	27.11	33.37	25.85	32.71	29.13	27.26	27.09				
<i>Min</i>	20.13	20.46	20.27	20.24	19.31	19.00	20.79	22.10	20.19	20.21	19.59	18.70	18.70		33.37	
<i>Difference</i>	2.6	4.1	1.7	6.7	8.2	8.1	12.6	3.8	12.5	8.9	7.7	8.4				
<b>Feeder 4</b>																
<i>Phase A</i>	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00				
<i>Phase B</i>	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00				
<i>Phase C</i>	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00				
<i>Max</i>	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00				
<i>Min</i>	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00		0.00	
<i>Difference</i>	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0				
<b>Feeder 5</b>																
<i>Phase A</i>	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00				
<i>Phase B</i>	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00				
<i>Phase C</i>	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00				
<i>Max</i>	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00				
<i>Min</i>	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00		0.00	
<i>Difference</i>	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0				